

# NOVATO FIRE PROTECTION DISTRICT FIRE LOSS MANAGEMENT DIVISION



Developed by \_\_\_\_\_  
Forrest M. Craig, Fire Marshal

Approved by \_\_\_\_\_  
Marc Revere, Fire Chief

Fire Protection Standard 210

## ROADWAY, DRIVEWAY AND BRIDGE DESIGN STANDARD

Date: 12/31/01

Revision: 4/23/07

Page: 1 of 4

This Standard has been developed pursuant to Article 9, Uniform Fire Code and the California Public Resources Code for State Responsibility Areas (SRA), as adopted by Ordinance by the Novato Fire Protection District. It is intended that this standard be used as the minimum dimensions, engineering, and all weather surface criterion for all roads and driveways installed within the service area of the Novato Fire Protection District.

### 1. GENERAL

This Fire Protection Standard takes precedence over City of Novato and County of Marin roadway and driveway design standards and criteria except where noted. For commercial and residential turn around minimum dimensions and engineering criteria, see additional Fire Protection Standards #211 through #215.

Roadways and driveways shall be installed prior to framing. At minimum, the first lift of A/C paving or concrete shall be installed as the minimum sub-base material and capable of supporting the designated gross vehicle weights specified below, prior to framing.

### 2. ROADWAYS

#### Width:

The minimum net horizontal unobstructed clearance shall be not less than 20 feet exclusive of gutters curbs and shoulders for roadways serving residential areas and shall be not less than 40 feet exclusive of gutters curbs and shoulders for roadways serving commercial areas.

Exception: Minimum roadway widths shall conform to City of Novato and County of Marin street classifications and in no case be less than 20 feet.

#### Vertical Clearance:

The minimum net vertical unobstructed clearance shall be not less than 14 feet.

#### Maximum Grade:

The maximum allowable grade for roadways shall be 18%.

Exception: Grades between 18% and 22% may be allowed with the expressed written approval of the Fire Marshal provided the length of that portion of the roadway does not exceed 100 feet, and that the sections immediately preceding and proceeding that portion of roadway for a distance of 200 feet on both sides, has grades not greater than 15%. This exception shall not be applied at fire hydrant locations and required fire apparatus turn-outs.

The maximum allowable cross slope shall not exceed 8%.

# NOVATO FIRE PROTECTION DISTRICT FIRE LOSS MANAGEMENT DIVISION



Developed by \_\_\_\_\_  
Forrest M. Craig, Fire Marshal

Approved by \_\_\_\_\_  
Marc Revere, Fire Chief

Fire Protection Standard 210

## ROADWAY, DRIVEWAY AND BRIDGE DESIGN STANDARD

Date: 12/31/01

Revision: 4/23/07

Page: 2 of 4

### **All Weather Surface (AWS) Defined:**

All weather surface (AWS) shall mean A/C paving, or concrete capable of supporting 60,000 gross vehicle weight. Grades up to and including 18% may be of A/C paving. Grades greater than 18% shall be of concrete curb-cut so as to allow for water run-off and traction. Turf block and similar products are not permitted.

### **Turns and Curvatures:**

No roadway shall have a horizontal inside radius of curvature of less than fifty (50) feet.

### **Dead ends and Turnaround:**

Dead end roads shall not exceed 800 feet. All roadways exceeding 150 feet in length shall have an approved cul-de-sac turn around located at the end of the roadway designed to Novato Fire District Fire Protection Standards for residential and commercial areas.

### **No Parking Fire Lane Signs and Posting:**

All roadways, turn arounds, and turn outs are designated Fire Lanes. Parking is not permitted within the required clearance widths and shall be posted in accordance with Novato Fire Protection District Standard #204. Signs on public streets within the City of Novato shall conform to the traffic engineering requirements of the City of Novato.

### **Gates:**

If gates are installed across roadways, the owner, applicant or developer shall first obtain approval from the City of Novato or County of Marin respective of jurisdiction. Gates shall not encroach into the minimum 20 ft. wide fire access width and shall have a minimum net clearance of two feet on both sides of street in addition to the required 20 ft. fire access width. Gates shall be equipped with key access in accordance with Novato Fire Protection District Standard #202.

Gates shall be set back from roadways a minimum of 30 feet or more so as not to cause cross traffic to stop or create a hazardous traffic condition on the roadway approach to the driveway.

## **3. DRIVEWAYS**

### **Width:**

The minimum net horizontal unobstructed clearance shall not be less than 16 feet exclusive of curbs and shoulders.

Note: When used for 2, up to 4 dwellings, reference "Limited Residential Street" in City/County development standards.

# NOVATO FIRE PROTECTION DISTRICT FIRE LOSS MANAGEMENT DIVISION



Developed by \_\_\_\_\_  
Forrest M. Craig, Fire Marshal

Approved by \_\_\_\_\_  
Marc Revere, Fire Chief

Fire Protection Standard 210

## ROADWAY, DRIVEWAY AND BRIDGE DESIGN STANDARD

Date: 12/31/01

Revision: 4/23/07

Page: 3 of 4

### **Vertical Clearance:**

The minimum net vertical unobstructed clearance shall be not less than 14 feet.

### **Maximum Grade:**

The maximum allowable grade for driveways shall be 18%, measured along both sides of a driveway.

Exception: Grades between 18% and 22% may be allowed with the expressed written approval of the Fire Marshal provided the length of that portion of the driveway does not exceed 100 feet, and that the section immediately preceding and proceeding that portion of driveway for a distance of 200 feet on both sides, has grades not greater than 17%. This exception shall not be applied at fire hydrant locations and required fire apparatus turn-outs.

The maximum allowable cross slope shall not exceed 6%.

### **All Weather Surface Defined:**

All weather surface (AWS) shall mean A/C paving, or concrete capable of supporting 40,000 gross vehicle weight. Grades up to and including 18% may be of A/C paving. Grades greater than 18% shall be of concrete curf-cut so as to allow for water run-off and traction. Turf block and similar products are not permitted.

### **Turns and Curvatures:**

The inside edge radius shall not be less than 27 feet.

### **Turn-outs:**

When driveways exceed 300 feet or when required to accommodate relay pumping at a fire hydrant as determined by the Fire Marshal, approved turn-outs in driveways shall be provided for and designed so as to accommodate Novato Fire District apparatus. The turn-out shall be installed at 300 foot intervals and not be less than 40 feet in length, exclusive of entrance and exit tapers. Turnouts shall be not less than 8 ½ feet in width. In no case shall the width of the turn-out and the driveway be less than 24 ½ feet. Grades at the turnout shall be no greater than 15%.

### **Dead ends and Turnaround:**

Dead end driveways shall not exceed 800 feet. All driveways exceeding 150 feet in length shall have an approved turnaround designed to Novato Fire District Fire Protection Standards and so located to within 100 feet from the end of the driveway.

# NOVATO FIRE PROTECTION DISTRICT FIRE LOSS MANAGEMENT DIVISION



Developed by \_\_\_\_\_  
Forrest M. Craig, Fire Marshal

Approved by \_\_\_\_\_  
Marc Revere, Fire Chief

Fire Protection Standard 210

## ROADWAY, DRIVEWAY AND BRIDGE DESIGN STANDARD

Date: 12/31/01

Revision: 4/23/07

Page: 4 of 4

### **No Parking Fire Lane Signs and Posting:**

All driveways, turn arounds, and turn outs are designated Fire Lanes. Parking is not permitted within the required clearance widths and shall be posted in accordance with Novato Fire Protection District Standard #204.

### **Gates:**

If gates are installed across driveways, the owner, applicant or developer shall first obtain approval from the City of Novato or County of Marin respective of jurisdiction. Gates shall not encroach into the required fire access width and shall have a minimum net clearance of two feet on both sides of the driveway in addition to the required 16 ft. or 20 ft. fire access width, which ever is applicable. Gates shall be equipped with key access in accordance with Novato Fire Protection District Standard #202.

Gates shall be set back from roadways a minimum of 30 feet or more so as not to cause cross traffic to stop or create a hazardous traffic condition on the roadway approach to the driveway.

## **4. BRIDGES SERVING RESIDENTIAL DRIVEWAYS**

### **Width:**

The minimum net horizontal unobstructed clearance shall be not less than 16 feet exclusive of curbs and shoulders.

### **Vertical Clearance:**

The minimum net vertical unobstructed clearance shall be not less than 14 feet.

### **Load Design, Testing, and Marking:**

Bridges serving residential driveways shall be engineered for a minimum 40,000 lbs of gross vehicle weight. All bridges shall have affixed to each approach side of the bridge a reflective permanent metal sign that indicates the engineered maximum vehicle weight. Signs shall have black letters and numerals at least 3 inches in height with a one-inch stroke and on a yellow reflective metal panel.

Bridges shall be load tested and certified once every ten (10) years, where structural integrity is in question and when required by the Fire Marshal, by an approved and California licensed structural engineer.